



NEW EQUIPMENT

2023 Chiller Incentive



APPLICATION INSTRUCTIONS

Fill out Steps 1-3 and submit to your utility provider. **Do not sign Steps 5-6 until instructed by your utility provider.**

STEP 1 CUSTOMER INFORMATION

Select your utility company: ☐ Eversource ☐ Liberty ☐ NH Electric Co-op ☐ Unitil Date: _____

Electric Account #: _____ Natural Gas Account #: _____

Company Name: _____ Contact Person: _____

Phone Number: _____ Contact Email: _____

Installation Address: _____ City: _____ State: _____ Zip: _____

Mailing Address: _____ City: _____ State: _____ Zip: _____

STEP 2 CONTRACTOR INFORMATION (if self-installed leave blank)

Contractor Company (if applicable): _____ Contact Person: _____

Mailing Address: _____ City: _____ State: _____ Zip: _____

Contact Phone: _____ Contact Email: _____

STEP 3 PAYEE INFORMATION

Check Payable to: ☐ Customer ☐ Contractor ☐ Other Payment To: _____

Mailing Address: _____ City: _____ State: _____ Zip: _____

LIBERTY CUSTOMERS ONLY – Signature (for payment to Contractor/Other): _____

STEP 4 RETURN APPLICATION TO UTILITY REPRESENTATIVE

Send to your utility representative or email to your utility here:

Eversource: efficiencynh@eversource.com

Liberty: nhsaves@libertyutilities.com

New Hampshire Electric Co-op: solutions@nhec.com

Unitil: efficiency@unitil.com

STEP 5 PRE APPROVAL OFFER

STOP Once you have received Utility Pre-approval notification, sign below accepting incentive offer, payment arrangement, and Program Terms and Conditions.

Utility Signature: _____ Date: _____

Amount Of Incentive: _____ Valid Through: _____

CUSTOMER SIGNATURE: _____ Date: _____

STEP 6 PROJECT COMPLETION

STOP Sign below to indicate that project is completed. Send final signed application to Utility.

Final Incentive calculated based on 'as-installed' conditions.

Utility Signature: _____ Date: _____

CUSTOMER SIGNATURE: _____ Date: _____

Final Project Cost: _____ Final Incentive Amount: _____

Powered by:

EVERSOURCE



June 28, 2023

NE&C CHILLER INCENTIVE WORKSHEET

ELIGIBILITY REQUIREMENTS		PROPOSED EQUIPMENT		REBATES				
Unit Size ARI Net Tons (A)	Minimum Performance Requirements, FL or IPLV (B)	Net Tons (C)	Proposed Efficiency (D)	Base Incentive (Per Ton) (E)	Base Incentive Total (F)	Performance Incentive Per Ton (Max of 2 times base rebate) (G)	Performance Incentive Total (H)	Total Incentive (F+H)
Air Cooled Chillers								
< 150 tons	FL: 10.19 IPLV: 15.83	_____	_____	\$20.00	\$_____	\$3.25	\$_____	\$_____
≥ 150 tons	FL: 10.19 IPLV: 16.13	_____	_____	\$20.00	\$_____	\$3.25	\$_____	\$_____
Water Cooled Chillers-Rotary Screw & Scroll								
≥ 75 and < 150 tons	FL: 0.713 IPLV: 0.466	_____	_____	\$11.00	\$_____	\$2.50	\$_____	\$_____
≥ 150 and < 300 tons	FL: 0.646 IPLV: 0.418	_____	_____	\$18.00	\$_____	\$3.00	\$_____	\$_____
≥ 300 tons and < 600 tons	FL: 0.594 IPLV: 0.390	_____	_____	\$18.00	\$_____	\$3.00	\$_____	\$_____
Water Cooled Chillers Centrifugal								
≥ 150 tons	FL: 0.571 IPLV: 0.418	_____	_____	\$20.00	\$_____	\$3.50	\$_____	\$_____
≥ 150 and < 300 tons	FL: 0.603 IPLV: 0.380	_____	_____	\$17.00	\$_____	\$1.25	\$_____	\$_____
≥ 300 and < 400 tons	FL: 0.513 IPLV: 0.371	_____	_____	\$10.00	\$_____	\$1.75	\$_____	\$_____
≥ 400 tons	FL: 0.556 IPLV: 0.361	_____	_____	\$10.00	\$_____	\$1.75	\$_____	\$_____

INCENTIVE CALCULATIONS:

NOTES
<ol style="list-style-type: none"> Incentive is available only for comfort cooling applications operating for min. 800 equivalent full load hours (EFLH) or 1500 run hours. Process chillers or chillers equipped with variable speed drives must be evaluated as a Custom Incentive. Proposed comfort cooling chiller shall meet or exceed the FL or IPLV efficiencies as listed in above table (B). Chiller equipment efficiency criteria are based on ARI Standard 550/590-98 at ARI standard conditions (see note 6) using a non-CFC refrigerant. Attach copy of manufacturer's performance sheet showing both Full Load (FL) and Integrated Part Load Value (IPLV) efficiencies (KW/ton). Air cooled chiller efficiencies shall include condenser fan energy consumption. Tons should be ARI net capacity, not gross capacity. Incentives for chillers shall be calculated using FL (Full Load) or IPLV (Integrated Part Load Value) efficiency ratings. The total Incentive (I) for air cooled chiller projects with efficiencies based on EER is calculated as follows: $F = \text{base incentive (C x E)} \text{ and } H = \text{performance incentive (using either FL or IPLV EER): } (D-B) \times 10 \times C \times G \text{ (performance incentive is for each 0.1 EER point above minimum criteria and may not exceed twice the base incentive)}$ The total incentive (I) for water cooled chiller projects with efficiencies based on kW / ton is calculated as follows: $F = \text{base incentive (C x E)} \text{ and } H = \text{performance incentive (using FL or IPLV kW/ ton): } (B-D) \times 100 \times C \times G \text{ (performance incentive is for each 0.01 KW/ton below maximum criteria and may not exceed twice the base incentive)}$ All water-cooled chillers shall incorporate condenser water reset strategy. ARI Chiller standard 550/590-98 conditions are as follows: <ul style="list-style-type: none"> 44° F leaving chiller water, 2.4 GPM / ton, 95° F entering condenser air temperature (air cooled only), 85° F entering condenser water temperature (water cooled only), 3.0 GPM / ton condenser water flow rate (water cooled only) Water cooled chillers must be equipped with condenser water reset strategy.

2023 Chiller New Equipment

Instructions for completing the NE&C CHILLER Incentive Worksheet

Requirements:

1. This Incentive is available only for comfort cooling applications operating for min. 800 equivalent full load hours (EFLH) or 1500 run hours. Process chillers or chillers equipped w/ variable speed drives may be evaluated as a Custom Incentive.
2. Project is NOT eligible for incentives on this application if equipment has been purchased and participated in the NHSaves mid-stream instant incentive program or received an incentive through any other NHSaves programs.
3. Proposed comfort cooling chiller shall meet or exceed the FL or IPLV efficiencies as listed in on Incentive form.
4. Chiller equipment efficiency criteria are based on ARI Standard 550/590-98 at ARI standard conditions (see note 6) using a non-CFC refrigerant. Attach copy of manufacturer's performance sheet showing both Full Load (FL) and Integrated Part Load Value (IPLV) efficiencies (kW/ton). Air cooled chiller efficiencies shall include condenser fan energy consumption. Tons should be ARI net capacity, not gross capacity. Incentives for chillers shall be calculated using FL (Full Load) or IPLV (Integrated Part Load Value) efficiency ratings.
5. The total Incentive (I) for air cooled chiller projects with efficiencies based on EER is calculated as follows:
Total Incentive = Base Incentive (F) = (C x E) plus Performance Incentive (H) (using either FL or IPLV) = (D-B) x 10 x C x G (performance Incentive is for each 0.1 EER point above minimum criteria and may not exceed twice the base Incentive)
6. The total Incentive (I) for water cooled chiller projects with efficiencies based on kW / ton is calculated as follows:
Total Incentive = Base Incentive F = (C x E) plus Performance Incentive H (using FL or IPLV kW/ ton) = (B-D) x 100 x C x G (performance Incentive is for each 0.01 KW/ton below maximum criteria and may not exceed twice the base Incentive)
7. All water-cooled chillers shall incorporate condenser water reset strategy.
8. ARI Chiller standard 550/590-98 conditions are as follows:
44° F leaving chiller water,
2.4 GPM / ton,
95° F entering condenser air temperature (air cooled only),
85° F entering condenser water temperature (water cooled only),
3.0 GPM / ton condenser water flow rate (water cooled only)
9. Chillers with VFD's shall have a minimum 3% impedance reactor in its AC power input connection.
10. Chiller equipment using chlorofluorocarbons (CFC's) as a refrigerant is not eligible for an Incentive. This includes the following refrigerant: CFC-11, CFC-12, and CFC-115 (R502).
11. The Incentive offer is not valid unless signed and dated by the Utility Representative. The Customer accepts the Utilities Incentive offer and agrees to the Terms and Conditions of the Utility by signing in the pre-approval offer block.
12. The Chiller Application must be completed and the Incentive approved prior to purchasing or installing the equipment.
13. Invoices will be required for payment of Incentive.
14. The Incentive, in conjunction with all other sources of funding, cannot exceed the total project cost.

Pre-Installation:

1. Review the Incentive eligibility requirements.
2. Review the proposed equipment specifications to confirm it meets the minimum efficiency requirements. Chillers must have both Full Load (FL) and Integrated Part Load Value (IPLV) efficiencies.
3. Provide to the utility representative the manufacturer's equipment specifications and record the following information on the worksheet: manufacturer/model number, unit size, unit efficiency, chiller tons and Full Load (FL) and Integrated Part Load Value (IPLV) efficiencies (kW/ton or EER).
4. Calculate the appropriate Incentive in the following examples:

2023 Chiller New Equipment

EXAMPLES OF HOW TO CALCULATE CHILLER INCENTIVES:

ELIGIBILITY REQUIREMENTS		PROPOSED EQUIPMENT		INCENTIVES				
Unit Size ARI Net Tons	Minimum Performance Requirements, FL or IPLV	Net Tons	Proposed Efficiency	Base Incentive (per ton)	Base Incentive Total	Performance Incentive per ton (Max of 2 times base incentive)	Performance Incentive Total (H) (See examples)	Total Incentive (F+H) (I)=(F+H)
(A)	(B)	(C)	(D)	(E)	(F) = (C * E)	(G)	(H)	(I)
Air Cooled Chillers								
< 150 tons	EER: FL: 10.52 IPLV: 13.75	125	FL: 9.8 IPLV: 14.2	\$20	\$2,500	\$3.25	\$1,829	\$4,329
Water Cooled Chillers — Centrifugal								
> 150 and < 300 tons	kW/ton: FL: 0.518 IPLV: 0.360	275	kW/ton: FL: 0.580 IPLV: 0.335	\$17	\$4,675	\$1.25	\$861	\$5,536

Ex 1: Incentive calculation for a 125 ton air cooled chiller unit with EER= 9.8 (FL) and EER = 14.2 (IPLV)

Unit does not meet Full Load minimum requirement (however, it does meet the IEEC 2009 Code) and meets IPLV minimum requirement so the unit qualifies for a Incentive.

Total Incentive = Base Incentive: (C * E) + Performance Incentive: (D - B) * 10 * C * G

Base Incentive = 125 tons * \$20/ton = \$2,500

Performance Incentive (using IPLV kW/ton values) = (14.2 - 13.75) * 10 * \$3.25 = \$14.63/ton, Incentive is 125 tons * \$14.63/ton = \$1,829 which is less than the maximum of 2 times the base Incentive

Total Incentive (I) = \$2,500 + \$1,829 = **\$4,329**

Ex 2: Incentive calculation for a 275 ton water cooled chiller unit with a FL kW/ton of 0.580 and IPLV kW/ton of 0.335

Unit does not meet Full Load minimum requirement (however, it does meet the IEEC 2009 Code) and meets IPLV minimum requirement so the unit qualifies for a Incentive.

Total Incentive = Base Incentive: F = C * E + Performance Incentive: H = (B - D) * 100 * C * G

Base Incentive = 275 tons * \$17/ton = \$4,675

Performance Incentive (using IPLV kW/ton values) = (0.360 - 0.335) * 100 * \$1.25 = \$3.13/ton, Incentive is 275 tons * \$3.13/ton = \$861 which is less the maximum Incentive of than 2 times the base Incentive.

Total Incentive (using IPLV kW/ton values), (I) = \$4,675 + \$861 = **\$5,536**

Post-Installation:

Utility Representative must verify that:

1. The Chiller has been installed and operable.
2. The installed chiller matches the Chiller Incentive Application information. If the equipment has changed from what was approved for the initial Incentive offer, the actual equipment specifications must be submitted and reviewed by the utility to verify compliance with technical requirements and approved before a Incentive is considered.
3. The invoice or proof of payment has been submitted.
4. The Utility Representative & Customer have signed & dated the post installation inspection block on the Incentive form.