

New Hampshire Instant HVAC Incentives

Qualifying Minimum Efficiency and Incentive Levels

Effective May 1, 2022



Heat Pumps

Equipment Type	Size Category	Full Load Cooling Efficiency	Part Load Cooling Efficiency	Heating Efficiency	Customer Incentive (\$/Ton)
Air Source Heat Pumps	<5.4 tons	12.5 EER	18 SEER	10 HSPF	\$250
	≥ 5.4 tons and < 11.3 tons	11.8 EER	13.6 IEER	3.4 COP	
	≥ 11.3 tons and < 20 tons	10.9 EER	12.8 IEER	3.3 COP	
	≥ 20 tons	10.1 EER	11.6 IEER	3.3 COP	
Air Source Variable Refrigerant Flow (VRF)	≥ 5.4 tons and < 11.3 tons	11.5 EER	20 IEER	3.4 COP	\$250
	≥ 11.3 tons and < 20 tons	11 EER	18 IEER	3.3 COP	
	≥ 20 tons	9.6 EER	18 IEER	3.3 COP	
Water Source Variable Refrigerant Flow (VRF)	≥ 5.4 tons and < 11.3 tons	12.5 EER	22 IEER	4.4 COP	\$250
	≥ 11.3 tons and < 20 tons	11 EER	20 IEER	4.2 COP	
	≥ 20 tons	11 EER	17 IEER	4 COP	
Water Source Heat Pump	< 11.3 tons	14 EER	-	4.6 COP	\$80
Ground Source Heat Pump (Ground Water; Water to Air)	< 11.3 tons	18 EER	-	4 COP	
Ground Source Heat Pump (Ground Loop; Brine to Air)	< 11.3 tons	15 EER	-	3.6 COP	

Air Conditioners

Equipment Type	Size Category	Full Load Cooling Efficiency	Part Load Cooling Efficiency	Customer Incentive (\$/Ton)
Air Conditioner	<5.4 tons	12.5 EER	15 SEER	\$70
	≥ 5.4 tons and < 11.3 tons	12 EER	13.8 SEER	\$50
	≥ 11.3 tons and < 20 tons	12 EER	13 IEER	
	≥ 20 tons and < 63.3 tons	10.3 EER	12.1 IEER	
	≥ 63.3 tons	9.7 EER	11.4 IEER	

Dual Enthalpy Economizer Controls (when installed with new qualifying equipment)

Equipment Type	Customer Incentive (\$/Unit)
Outside Air Economizer utilizing two enthalpy sensors (1 for outdoor & 1 for return air)	\$250

Note: Control Incentives not applicable when required by Energy Code.