

2026 Measure Eligibility Criteria

New Hampshire Commercial and Industrial Midstream Lighting | Effective January 2026

DesignLights Consortium® - Certified Products*

Product Type	Product Subtype	Primary Use	Category	General Application	Control Tiers Available**	Install Requirements
LED Troffer	1x4 Troffer	1x4 Luminaires for Ambient Lighting of Interior Commercial Spaces	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	N/A
	2x2 Troffer	2x2 Luminaires for Ambient Lighting of Interior Commercial Spaces	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	N/A
	2x4 Troffer	2x4 Luminaires for Ambient Lighting of Interior Commercial Spaces	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	N/A
	1x4 Troffer Retrofit Kit	<ul style="list-style-type: none"> Integrated Retrofit Kits for 1x4 Luminaires Linear Retrofit Kits for 1x4 Luminaires 	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	N/A
	2x2 Troffer Retrofit Kit	<ul style="list-style-type: none"> Integrated Retrofit Kits for 2x2 Luminaires Linear Retrofit Kits for 2x2 Luminaires 	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	N/A
	2x4 Troffer Retrofit Kit	<ul style="list-style-type: none"> Integrated Retrofit Kits for 2x4 Luminaires Linear Retrofit Kits for 2x4 Luminaires 	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	N/A
LED Linear Ambient	Linear Strip/Wrap	Direct Linear Luminaires	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	<ul style="list-style-type: none"> Installed height requirement: ≤12 feet Not installed in a stairwell
LED High or Low Bay	Low Bay	Low-Bay Luminaires for Commercial and Industrial Buildings	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	<ul style="list-style-type: none"> High/Low Bays must be used for downlighting only Low Bay installed height requirement: >12 feet and ≤20 feet Not installed in a stairwell
	High Bay	<ul style="list-style-type: none"> High-Bay Luminaires for Commercial and Industrial Buildings High-Bay Aisle Luminaires 	N/A	N/A	<ul style="list-style-type: none"> Occupancy Dual LLC 	<ul style="list-style-type: none"> High/Low Bays must be used for downlighting only High Bay installed height requirement: >20 feet Not installed in a stairwell

Product Type	Product Subtype	Primary Use	Category	General Application	Control Tiers Available**	Install Requirements
LED Exterior, Parking Garage, and Canopy	Exterior	<p>All except:</p> <ul style="list-style-type: none"> Stairwell and Passageway Luminaires <p>Specialty products:</p> <ul style="list-style-type: none"> Eligible: <ul style="list-style-type: none"> Specialty: Hazardous Wall Mounted Luminaires Specialty: Hazardous Flood and Spot Luminaires Specialty: Hazardous Area Lighting Ineligible: <ul style="list-style-type: none"> All other specialty products 	<ul style="list-style-type: none"> Outdoor Luminaires Outdoor Retrofit Kit 	N/A	Occupancy	N/A
	Parking Garage	<ul style="list-style-type: none"> Parking Garage Luminaires 	<ul style="list-style-type: none"> Outdoor Luminaires Outdoor Retrofit Kit 	N/A	Occupancy	N/A
	Canopy	<ul style="list-style-type: none"> Fuel Pump Canopy Luminaires Retrofit Kits for Fuel Pump Canopy Luminaires Specialty: Canopy Lighting 	<ul style="list-style-type: none"> Outdoor Luminaires Outdoor Retrofit Kit 	N/A	Occupancy	N/A
LED Stairwell	Stairwell Kit – Low output with sensor	Stairway and passageway luminaires	N/A	Low Output	Occupancy	Must be installed with occupancy sensor in stairwell
	Stairwell Kit – Mid output with sensor	Stairway and passageway luminaires	N/A	Mid Output	Occupancy	Must be installed with occupancy sensor in stairwell
LED Tube	2 ft T8	N/A	N/A	T8 Two-Foot	N/A	N/A
	3 ft T8	N/A	N/A	T8 Three-Foot	N/A	N/A
	4 ft T8	N/A	N/A	T8 Four-Foot	N/A	N/A
	8 ft T8	N/A	N/A	T8 Eight-Foot	N/A	N/A
	4 ft T5	N/A	N/A	<ul style="list-style-type: none"> T5 Four-Foot T5HO Four-Foot 	N/A	N/A
	T8 U-bend	N/A	N/A	U-bend Replacement Lamps	N/A	N/A

Product Type	Product Subtype	Primary Use	Category	General Application	Control Tiers Available**	Install Requirements
LED Mogul Lamp	Exterior Mogul Lamp	N/A	Mogul (E39) Screw-Base Replacements For HID Lamps	<ul style="list-style-type: none"> • Low Output • Mid Output • High Output • Very High Output 	N/A	N/A
	Mogul Interior Low Bay	N/A	Mogul (E39) Screw-Base Replacements For HID Lamps	Low Bay	N/A	N/A
	Mogul Interior High Bay	N/A	Mogul (E39) Screw-Base Replacements For HID Lamps	High Bay	N/A	N/A

* Source QPLs can be found at the following link: [DLC](#)

** Refer to the table below for further information on Control Tiers

Control Tier	Required Control Features Listed on DLC	Other Requirements
Occupancy Sensor	Occupancy Sensing: Yes OR Multifunction Sensor: Yes OR Integral Control Capability: LLLC	Must be installed with integrated occupancy sensor
Dual Sensor	Occupancy Sensing: Yes AND Daylight Sensing: Yes OR Multifunction Sensor: Yes OR Integral Control Capability: LLLC	Must be installed with dual sensor (daylight and occupancy)
LLLC/NLC	Integral Control Capability: LLLC	Must be installed with an integrated sensor and be part of a networked and commissioned lighting control system

For more information:

Contact us at lighting-ne@energy-solution.com or (510) 852-8491.

